



MATERIAL LIST

ALL PVC SCHEDULE 80 WILL BE THREADED EXCEPT AS NOTED

- 1. POLYETHYLENE PRESSURE PIPE SDR 11 (EACH LEG)
- 2. UNION BALL VALVE (PVC) 1 EACH LEG
- 3. FEMALE PIPE THREAD X HUB ADAPTER AND PLUG 1 EACH LEG
- 4. WYE (PVC) 1 EACH LEG
- 5. NIPPLE PVC (EACH LEG/LENGTH TO SUIT)
- 6. SS TRANSITION COUPLING 316 SS MPT (THRD IP X PE HDPE)
- 7. PRECAST SOLID BLOCKS



City of Bremerton

PUBLIC WORKS

DESIGN/CONSTRUCTION STANDARDS

**MULTI-DIRECTIONAL
LOW PRESSURE
CLEAN-OUT (TYP)
PLAN VIEW**

Alteration of this drawing is prohibited. Any approval of an altered drawing is unauthorized and void.

6124

**Revision Date
8/27/10**