



- NOTE:**
- 1 REFER TO PLANS FOR LOCATIONS OF ADDITIONAL CONDUIT RUNS NOT SHOWN HERE.
 - 2 WIRE SIZES SHALL BE PER WIRING SCHEDULE
 - 3 2" CONDUIT NOT SHOWN
 - 4 FOR FOUNDATION DETAILS SEE STATE STANDARD PLAN J-1B FOR FIXED OR SLIP BASES.
 - 5 ALL CONDUITS TO BE EXTENDED TO PROJECT LIMITS
 - 6 SCHEDULE 80 PVC CONDUIT UNDER ROADWAYS AND DRIVEWAYS.
 - 7 INSULATED MULTI-WIRE CONNECTOR BLOCK (POLARIS OR ILSCO) MAY BE USED TO SPLICE IN JUNCTION BOXES FOR ALL APPLICATIONS EXCEPT DETECTION LOOPS.
 - 8 J-BOX TO BE SIZED PER NEC



City of Bremerton
PUBLIC WORKS
ENGINEERING DIVISION

JUNCTION BOX DETAIL

Alteration of this drawing is prohibited. Any approval of an altered drawing is unauthorized and void.

DRAWING NO.
7010
REVISION DATE:
8/01/17