



NOTES:

1. CONCRETE UNIT PAVER AREA WIDTH VARIES PER PLAN.
2. CONCRETE BASE CROSS SLOPE WILL BE SAME AS FINISH PAVEMENT CROSS SLOPE.
3. GRADING REQUIREMENTS OF ASTM C144 WITH MODIFICATIONS
(SEE ATTACHMENT).
4. CONCRETE BASE AND CURB WILL HAVE MIN COMPRESSIVE STRENGTH OF 3000 PSI.

 <p>City of Bremerton</p> <p>PUBLIC WORKS</p> <p>ENGINEERING DIVISION</p>	<p>CONCRETE UNIT PAVER CROSSWALK</p> <p>SECTION</p> <p>DOWNTOWN LOCATIONS</p> <p><small>Alteration of this drawing is prohibited. Any approval of an altered drawing is unauthorized and void.</small></p>	<p>3261</p> <p><small>Revision Date</small> 8/15/08</p>