



NOTES:

1. "D", THE INSIDE DIAM. OF THE INLET PIPE, SHALL BE 8" OR LESS. FOR LARGER VALUES OF "D", USE A MANHOLE OR CATCH BASIN.
2. IN NO CASE SHALL THE OUTSIDE DIAM. OF THE INLET PIPE EXCEED ONE-HALF THE INSIDE DIAM. OF THE MAIN STORM DRAIN PIPE.
3. CENTERLINE OF INLET PIPE SHALL BE ON RADIUS OF MAIN STORM DRAIN.
4. THE MAX. OPENING INTO THE EXISTING STORM DRAIN SHALL BE THE OUTSIDE DIAM. OF THE INLET PIPE PLUS 1 IN.
5. IF IS GREATER THAN 45° FIELD TAPPING IS NOT ALLOWED.
6. MAINLINE SHALL HAVE 12" MIN. DIAM.
7. FOR DISSIMILAR PIPES UP TO 24", CORE DRILL MAIN AND CONNECT WITH SADDLE TEE.
8. PRIOR APPROVAL FROM CITY ENGINEER REQUIRED

	<p>City of Bremerton</p> <hr/> <p>PUBLIC WORKS</p> <hr/> <p>DESIGN/CONSTRUCTION STANDARDS</p>	<p>STORMWATER SEWER CONNECTION</p> <p>TO CONCRETE PIPE</p>	<p>4050</p>
	<p>Alteration of this drawing is prohibited. Any approval of an altered drawing is unauthorized and void.</p>		<p>Revision Date 11/10/15</p>