


POST INDICATOR VALVE (PIV)

NOTES:

1. PIV SHALL BE LOCATED AT LEAST 5' FROM BUILDING OR STRUCTURE.
2. PIV REQUIRES 36" OF UNOBSTRUCTED CLEARANCE AROUND THE PERIMETER OF PIV STANDPIPE.
3. "OPEN" AND "SHUT" TARGETS MUST BE SET FOR THE APPROPRIATE VALVE SIZE.

	<p>City of Bremerton</p> <hr style="width: 50%; margin: 0 auto;"/> <p>PUBLIC WORKS</p>	<p><u>POST INDICATOR VALVE</u></p> <p style="font-size: small;">Alteration of this drawing is prohibited. Any approval of an altered drawing is unauthorized and void.</p>		
<p>DESIGN/CONSTRUCTION STANDARDS</p>	<table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <td style="text-align: center; padding: 5px;">5087</td> </tr> <tr> <td style="text-align: center; padding: 2px;">Revision Date</td> </tr> <tr> <td style="text-align: center; padding: 2px;">04/19/21</td> </tr> </table>	5087	Revision Date	04/19/21
5087				
Revision Date				
04/19/21				