



**NOTE:**

1. ALL 2" GALVANIZED PIPE ABOVE GROUND TO BE PAINTED HIGH RUSTOLEUM GLOSS BLUE.
2. AIR/VAC TO BE BURIED AS SHOWN FOR FREEZE PROTECTION. LOCATION OF RISER SECTION TO BE APPROVED BY ENGINEER PRIOR TO INSTALLATION.
3. TAP INTO AN "EXISTING" WATER MAIN, SHALL BE COMPLETED BY BREMERTON UTILITIES CREW.
4. LOCATE WIRE SHALL BE 12 GA. BLUE COATED SOLID COPPER WIRE, STRIPPED AT BOTH ENDS AND TIGHTLY WRAPPED AROUND (GROUNDED TO) THE CORPORATION STOP A MINIMUM OF 2 TIMES OR CRIMPED TO THE LOCATING WIRE ON THE MAIN .



**City of Bremerton**

**PUBLIC WORKS**

**DESIGN/CONSTRUCTION STANDARDS**

**2" AIR & VACUUM RELEASE  
VALVE ASSEMBLY**

Alteration of this drawing is prohibited. Any approval of an altered drawing is unauthorized and void.

**5320**

Revision Date  
04/23/21